

*Luke Schroeder*

Lead Consulting and Inspection, Inc.

NJ Dept. of Health Lead Permits

Inspector/Risk Assessor #001615

Plan/Designer #001609

Supervisor/Housing & Public Building #001537

Supervisor/Commercial Bldg & Steel Structures #007837

NJ Dept. of Community Affairs Lic #00121-E

## ***Water Certification***

**Name:** Kidz R First  
506 East State Street  
Trenton, NJ 08609  
Phone: 609-529-8871

**Inspection Address:** 506 East State Street  
Trenton, NJ 08609

**Inspection date:** March 25, 2022

**Water Outlet Tested:**

1 <sup>st</sup> floor / Kitchen / Sink	Pass
1 <sup>st</sup> floor / Boys / Sink	Pass
2 <sup>nd</sup> floor / Hallway / Left sink	Pass
2 <sup>nd</sup> floor / Hallway / Right sink	Pass
2 <sup>nd</sup> floor / Hallway / Left sink	Pass
2 <sup>nd</sup> floor / Hallway / Right sink	Pass

**EPA Standard:** Copper <1300 PPB                      Lead <15 PPB

**Certification:** Drinking water meets EPA Standards  
See reports from *(Environmental Hazard Services, LLC.)*

**Operator License:** 00121-E



G. Luke Schroeder  
NJ dept of Health ID# 001537