

Luke Schroeder

Lead Consulting and Inspection, Inc.

NJ Dept of Health Lead Permits
Inspector/Risk Assessor #001615
Plan/Designer #001609
Supervisor/Housing & Public Building #001537
Supervisor/Commercial Bldg. & Steel Structures #007837
NJ Dept. of Community Affairs Lic. #00121-E

Water Certification

Name: Kids R First
415 Greenwood Avenue (Rear)
Trenton, NJ
Phone:

Inspection Address: 415 Greenwood Avenue (Rear)
Trenton, NJ

Inspection date: August 23, 2022

Water Outlet Tested:	1 st floor / Classroom / Sink	Pass
	1 st floor / Kitchen / Sink	Pass
	1 st floor / Classroom / Sink	Pass
	1 st floor / Classroom / Sink	Pass

EPA Standard: Copper <1300 PPB Lead <15 PPB

Certification: Drinking water meets EPA Standards
See reports from (*Phoenix Environmental Laboratories, Inc.*)

Operator License: 00121-E

G. Luke Schroeder
NJ dept of Health ID# 001537

Bldg 2 (B)



Lead Consulting and Inspection, Inc.

NJ Dept. of Health Lead Permits

Inspector/Risk Assessor #001615

Plan/Designer #001609

Supervisor/Housing & Public Building #001537

Supervisor/Commercial Bldg. & Steel Structures #007837

NJ Dept. of Community Affairs Lic #00121-E

Water Certification

Name: Kids R First Preschool
415 Greenwood Avenue
Trenton, NJ
Phone: 609-306 8989

Inspection Address: 415 Greenwood Avenue
Trenton, NJ

Inspection date: September 23, 2022

Water Outlet Tested:	1 st floor / Front Classroom / Classroom sink	Pass
	1 st floor / Rear Classroom / Classroom sink	Pass
	1 st floor / Hallway / Bath sink	Pass
	2 nd floor / Front Classroom / Classroom Sink	Pass
	2 nd floor / Kitchen / Sink	Pass
	2 nd floor / Rear Classroom / Bath sink	Pass

EPA Standard: Copper <1300 PPB Lead <15 PPB

Certification: Drinking water meets EPA Standards
See reports from *(Phoenix Environmental Laboratories, Inc.)*

Operator License: 00121-E

G. Luke Schroeder
NJ dept of Health ID# 001537

BLW C
3

Luke Schroeder

Lead Consulting and Inspection, Inc.

NJ Dept. of Health Lead Permits

Inspector/Risk Assessor #001615

Plan/Designer #001609

Supervisor/Housing & Public Building #001537

Supervisor/Commercial Bldg & Steel Structures #007837

NJ Dept. of Community Affairs Lic. #00121-E

Water Certification

Name: Kids R First
415 Greenwood Avenue (Rear right)
Trenton, NJ
Phone:

Inspection Address: 415 Greenwood Avenue (Rear right)
Trenton, NJ

Inspection date: December 17, 2022

Water Outlet Tested: 1st floor / Classroom 2 / Sink Pass
1st floor / Classroom 1 / Sink Pass

EPA Standard: Copper <1300 PPB Lead <15 PPB

Certification: Drinking water meets EPA Standards
See reports from *(Phoenix Environmental Laboratories, Inc.)*

Operator License: 00121-E



G. Luke Schroeder
NJ dept of Health ID# 001537