

Luke Schroeder

Lead Consulting and Inspection, Inc.

NJ Dept. of Health Lic. #001615

Inspector/Risk Assessor #001615

Plan/Designer #001609

Supervisor/Housing & Public Building #001537

Supervisor/Commercial Bldg. & Steel Structures #007837

NJ Dept. of Community Affairs Lic. #00121-E

Water Certification

Name: Kids-R-First
1676 North Olden Avenue
Ewing Township, NJ 08638
Phone:

Inspection Address: 1676 North Olden Avenue
Ewing Township, NJ 08638

Inspection date: June 22, 2022


Water Outlet Tested:

1 st floor / Classroom 2 / Sink	Pass
1 st floor / Classroom 1 / Sink	Pass
1 st floor / Classroom 3 / Sink	Pass
1 st floor / Classroom 4 / Sink	Pass
1 st floor / Boys bath / Sink 2	Pass
1 st floor / Boys bath / Sink 4	Pass
1 st floor / Girls bath / Sink 1	Pass
1 st floor / Girls bath / Sink 3	Pass
2 nd floor / Classroom 5 / Sink	Pass
2 nd floor / Classroom 6 / Sink	Pass
2 nd floor / Classroom 7 / Sink	Pass
2 nd floor / Classroom 8 / Sink	Pass

EPA Standard: Copper <1300 PPB Lead <15 PPB

Certification: Drinking water meets EPA Standards
See reports from (*Phoenix Environmental Laboratories, Inc.*)

Operator License: 00121-E



G. Luke Schroeder
NJ dept of Health ID# 001537

Lead Consulting and Inspection, Inc. • 219 Main Street, P.O. Box 814, Chatham, NJ 07928
Business Line: (973) 912-0222 E-Mail: Luke973@verizon.net Fax: (973) 912-5227