



Lead Consulting and Inspection, Inc.

NJ Dept. of Health Lead Permits

Inspector/Risk Assessor #001615

Plan/Designer #001609

Supervisor/Housing & Public Building #001537

Supervisor/Commercial Bldg. & Steel Structures #007837

NJ Dept. of Community Affairs Lic. #00121-E

## Water Certification

**Name:** Kidz R First  
635 South Clinton Avenue  
Trenton, NJ  
Phone:

**Inspection Address:** 635 South Clinton Avenue  
Trenton, NJ

**Inspection date:** March 25, 2022

<b>Water Outlet Tested:</b>	1 <sup>st</sup> floor / Girls bath / Left sink	Pass
	1 <sup>st</sup> floor / Girls bath / Right sink	Pass
	1 <sup>st</sup> floor / Boys bath / Middle sink	Pass
	1 <sup>st</sup> floor / Kitchen / Sink	Pass
	1 <sup>st</sup> floor / Classroom / Sink	Pass

**EPA Standard:** Copper <1300 PPB                      Lead <15 PPB

**Certification:** Drinking water meets EPA Standards  
See reports from (*Environmental Hazard Services, LLC.*)

**Operator License:**                      00121-E

G. Luke Schroeder  
NJ dept of Health ID# 001537